

McCullough, Kirsten J.

From: Jon Roberts <Jon.Roberts@deq.ok.gov> on behalf of DEQ EnvReviews <EnvReviews@deq.ok.gov>
Sent: Monday, May 11, 2020 1:20 PM
To: McCullough, Kirsten J.
Subject: Environmental Review

Categories: Filed by Newforma

Dear Ms. McCullough:

In response to your request, we have completed a general environmental review for the project listed below.

Project

Letter dated April 27, 2020 – Proposed Market Road Detention Pond, City of Altus, Jackson County, OK [34.646, -99.349]

Comment

While no adverse environmental impacts under DEQ jurisdiction are anticipated, please be aware of the following regulatory requirements.

A. Prior to beginning any construction activity disturbing more than one acre, you must submit an NOI and obtain authorization under OKR10, construction stormwater. If you need assistance, please contact DEQ's Stormwater Unit at (405) 702-6100.

B. Water and wastewater infrastructure projects that will require a construction permit from DEQ's Water Quality Division include the following:

- Construction of new water and wastewater treatment facilities;
- Modifications and upgrades to existing facilities;
- Construction of new water distribution and wastewater collection lines;
- Relocation of existing water distribution and wastewater collection lines.

Projects that do not require a construction permit include:

- Replacement of existing equipment with same type and size equipment;
- Replacement of existing water and wastewater lines with the same size line in the same location.

Please contact DEQ's Water Quality Division (Construction Permitting Section) if you have specific questions about these projects or need further clarification. Rocky Chen is the Manager of this section and can be reached at (405) 702-8140 or rocky.chen@deq.ok.gov.

Additional recommendations to consider may be found at <https://go.usa.gov/xVxyY>.

For future projects, please include GPS coordinates in decimal degrees (DD.DDD) and continue including street addresses, section/township/range, or other location information.

Thank you for the opportunity to provide our comments. If you have any questions or need clarification, please contact me.

Regards,

Jon A. Roberts, Senior Manager
Oklahoma Department of Environmental Quality
[Office of External Affairs](#)
P. O. Box 1677
707 N. Robinson Ave.
Oklahoma City, OK 73101-1677
Ph: (405) 702-7111

